



REFERENCE DRAWINGS	
ASSEMBLIES	NUMBER
SHOWERHEAD	9970-125-003
NOZZLE	9970-101-004
CARTRIDGES	
FLO-CLOZ	9975-000-001
METER-MATIC	9975-020-003
AIR-CONTROL	
SERVOMOTOR	9955-000-002
PUSHBUTTON	9957-300-001
AIR-CONTROL BODY	9975-090-001
CHECKSTOP/STRAINER	9956-040-003

INSTALLATION INSTRUCTIONS

- ROUGH IN FOR THE FOLLOWING; • 3/4" NPT STUB-OUT.
- A- SET ANCHOR BASE (1) BEFORE POURING CONCRETE, SCREW BOLTS (2) INTO ANCHOR PLATE ALL THE WAY DOWN SO AS TO KEEP THREADS CLEAN AND PROVIDE THREADS FOR BOLTS BELOW ANCHOR PLATE. (4) 5/16"-20 x 1" HEX HEAD BOLTS ARE FURNISHED WITH ANCHOR BASE. TOP OF BASE SHOULD BE FLUSH WITH FLOOR.
 - B- ASSEMBLE O-RING ADAPTER (3) TO 3/4" STUBOUT, ALIGN MOUNTING HOLES IN ADAPTER (3) TO (2) 1/4" HOLES IN HOLES ANCHOR BASE (1) SECURE WITH (2) 1/4"-20 x 3/8" BOLTS (6) PROVIDED.

- C- REMOVE BOLTS (2) FROM BASE, POSITION PYLON SHOWER (4) ENGAGING O-RING CONNECTION (5).
- D- SECURE PYLON SHOWER (4) TO ANCHOR BASE (1) WITH BOLTS PROVIDED (2) .

NOTE:
 MAXIMUM RECOMMENDED WORKING WATER PRESSURE IS 100 PSI; TEMPERATURE IS 130°F; OUTLET TEMPERATURE IS RECOMMENDED AT A MAXIMUM OF 105°F.

WARNING:
 PRIOR TO MAKING INSTALLATION, SUPPLY LINES MUST BE FLUSHED OF ALL FOREIGN MATERIAL SUCH AS PIPE DOPE, CHIPS, ETC. VALVE MUST BE DRAINED PRIOR TO BEING SUBJECTED TO FREEZING TEMPERATURES. MAXIMUM RECOMMENDED OUTLET WATER TEMPERATURE IS 105°F.

<p>ACORN ENGINEERING COMPANY P.O. BOX 3527 INDUSTRY, CA. 91744 (626) 336-4561 FAX (626) 961-2200</p>	<p>TITLE 900 SERIES PYLON SHOWER</p>		
	<p>MANUFACTURE DATE</p> <p>MARCH 1988</p> <p>TO PRESENT</p>	<p>DATE ISSUED</p> <p>1/18/94</p> <p>DATE REVISED</p> <p>3/7/97</p>	<p>DRAWING NUMBER</p> <p>9900-245-001</p>