



INSTALLATION INSTRUCTIONS:

- A- DISASSEMBLE PANEL ASSEMBLY ① FROM WALL MOUNTING FRAME ② BY REMOVING VANDAL RESISTANT SCREWS ③ FROM THE PANEL.
- B- INSTALL MOUNTING FRAME ② FLUSH WITH FINISHED WALL. BLOCKOUT FOR MOUNTING FRAME IS 14-5/8" x 16-5/8" x 3" DEEP. MINIMUM RECOMMENDED MOUNTING HEIGHT FOR FRAME IS 50-1/2" FROM THE TOP OF FRAME TO ABOVE FINISHED FLOOR.
- C- PROVIDE SUPPLY ROUGH-INS IN THE AREA ④ INDICATED. THOROUGHLY FLUSH SUPPLY LINES.
- D- MAKE-UP CONNECTIONS TO 1/2" NPS FLEX HOSE FEMALE ENDS ⑤ WHILE SUPPORTING PANEL OFF THE FLOOR. NOTE: SUPPLY INLET CONNECTION WILL ACCOMMODATE 1/2" NPT MALE ADAPTER.

REFERENCE DRAWINGS	
SAFTI-TROL	9975-032-001
SAFTI-TROL CARTRIDGE	9975-030-001

- E- SECURE PANEL ASSEMBLY ① TO MOUNTING FRAME ② WITH VANDAL RESISTANT SCREWS ③ PROVIDED.

NOTE: MAXIMUM RECOMMENDED WORKING WATER PRESSURE IS 100 PSI; MAXIMUM TEMPERATURE IS 130° F; OUTLET TEMPERATURE IS RECOMMENDED AT A MAXIMUM OF 105° F.

WARNING: PRIOR TO MAKING INSTALLATION, SUPPLY LINES MUST BE FLUSHED OF ALL FOREIGN MATERIAL SUCH AS PIPE DOPE, CHIPS, SOLDER, ETC. VALVE MUST BE DRAINED PRIOR TO BEING SUBJECTED TO FREEZING TEMPERATURES.



ACORN ENGINEERING COMPANY
P.O. BOX 3527 INDUSTRY, CA. 91744
(626) 336-4561 FAX (626) 961-2200

TITLE **2899 BEDPAN WASHER w/PRESSURE TYPE VACUUM BREAKER.**

MANUFACTURE DATE FEBRUARY 2004 TO PRESENT	DATE ISSUED 02/12/04	DRAWING NUMBER 9915-099-002
	DATE REVISED 06/22/04	